

DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive Joseph T. Parisi

1919 Alliant Energy Center Way • Madison, Wisconsin 53713 Phone: (608) 266-4018 • Fax: (608) 267-1533

Commissioner / Director Gerald J. Mandli

February 3, 2017

ATTENTION ALL REQUEST FOR PROPOSAL (RFP) HOLDERS RFP NO. 316039 - ADDENDUM NO. 2 BIOGAS CLEANING EQUIPMENT FOR PIPELINE INJECTION DANE COUNTY LANDFILL SITE #2 7102 U.S. HIGHWAY 12 & 18 MADISON, WISCONSIN

<u>PROPOSALS DUE</u>: TUESDAY, FEBRUARY 14, 2017, 2:00 PM. DUE DATE AND TIME <u>ARE NOT</u> CHANGED BY THIS ADDENDUM

This Addendum is issued to modify, explain or clarify the original Request for Proposal (RFP) and is hereby made a part of the RFP. <u>Proposers must acknowledge this addendum on the Addendum form and submit with Proposal as outlined in RFP Cover Letter.</u>

PLEASE MAKE THE FOLLOWING CHANGES:

1. Requested Services and Business Information

a. <u>Section 1 – General Information:</u>

Existing Conditions: The flow for the waste heat loop for several landfill buildings are approximately 80 gpm with a glycol concentration of approximately 35%.

b. Section 3 – Proposal Content, Paragraph 11:

SHALL READ:

Dane County requires assurance of the biogas cleaning system performance. Proposer shall indicate one of the following:

- a. Minimum of three (3) past projects with data acquired post-construction demonstrating percent run-time and minimum gas cleaning standards met; and/or
- b. Sample guarantee with percent run-time and minimum gas cleaning standards.

•	ot of the following addenda and in wledged:	clusion of their provision	s in this Proposal is hereby
	Addendum No(s).	_ through	-
	Dated		-
	Signature		

If any additional information about this Addendum is needed, please contact John Welch at (608) 516-4154, or welch@countyofdane.com.

RFP No. 316039 -2 - rev. 08/14